



**SECTION B-B**

**NOTES**

1. INSULATION SHALL BE A CELLULAR GLASS CONFORMING TO ASTM C-552, INSTALLED ACCORDING TO MANUFACTURER'S RECOMMENDATIONS.
2. THE PROTECTIVE COATING SHALL BE A 125 MIL PREFABRICATED LAMINATE CONTAINING A 10X10 ASPHALT IMPREGENATED GLASS FABRIC AND A 1 MIL ALUMINUM FOIL, SANDWICHED BETWEEN 3 LAYERS OF BITUMINOUS MASTIC. THE EXPOSED SURFACE IS COATED WITH A PROTECTIVE 4 MIL POLYETHYLENE PLASTIC FILM

<b>PHILADELPHIA WATER — DEPARTMENT —</b>	<b>EXPOSED WATER MAIN FROST PROTECTIVE COATING</b>		
	DRAWN BY: D&B GUARINO	DATE: FEB. 2022	
CHECKED BY: WD	DETAIL ID: INSTALL-09	REV.: 1	