



NOTES:

1. ALL LINES, FITTINGS AND TEST APPURTENANCES SHALL BE CAPABLE OF WITHSTANDING MAXIMUM TEST PRESSURE
2. PROVIDE ADEQUATE PROTECTION TO ALL LINES, FITTINGS AND TEST APPURTENANCES WHEN TESTING DURING FREEZING WEATHER
3. PUMP MUST BE CAPABLE OF APPLYING PRESSURE WITHIN TEST RANGE (PROVIDE FOR PRESSURE RELIEF ON PUMP)

PHILADELPHIA WATER — DEPARTMENT —	PRESSURE TEST SETUP			
	DRAWN BY:	D&B GUARINO	DATE:	FEB. 2022
	CHECKED BY:	WD	DETAIL ID: INSTALL-13	REV.: NEW