

# WATER ADVISORY

DATE DISTRIBUTED: 6/13/23

Philadelphia Water Department  
1101 Market St. 3rd Floor, Philadelphia PA 19107  
PWS ID#: PA 1510001

PHILADELPHIA  
**WATER**  
— DEPARTMENT —

Advisory for the following zipcodes: 19151, parts of 19131, parts of 19139



# Boil water advisory is over.

## No further action is required.

**What happened:** On June 11, 2023, a pump failure created a loss of pressure at a pumping station that serves parts of upper West Philadelphia. These conditions could allow contaminated water to enter the system, and your property's plumbing.

**How we corrected the issue:** We restored system pressure and water service. We flushed the water system thoroughly. We tested finished water, and found no evidence of coliform bacteria.



*Please share this information with people in the zip codes shown above who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You may post this notice in a public place or distribute copies by hand or mail.*

 **For Translation**  **(215) 685-6300**

Español | 國語 | Tiếng Việt | Русский | ភាសាខ្មែរ | 廣東話 | Português | Italiano

 **(215) 685-6300**