

## PAVING RESTORATION NOTES

- WHERE THE TRENCH WIDTH IS LESS THAN 3'-0", THE CONCRETE BASE RESTORATION SHALL COVER THE TRENCH AND EXTEND 9" OVER UNDISTURBED OR COMPACTED SOIL ON EACH SIDE OF THE TRENCH
- WHERE THE TRENCH WIDTH IS 3'-0" OR GREATER, THE CONCRETE BASE RESTORATION SHALL COVER THE TRENCH AND EXTEND 12" OVER UNDISTURBED OR COMPACTED SOIL ON EACH SIDE OF THE TRENCH
- SURFACE COURSE PAVING RESTORATION SHALL COVER THE WIDTH OF THE CONCRETE BASE AND EXTEND 6" BEYOND EXCEPT THAT BITUMINOUS CONCRETE SURFACE COURSE RESTORATION SHALL ONLY COVER THE RESTORED CONCRETE BASE
- REMOVAL OF BASE AND PAVING OUTSIDE OF TRENCH LIMITS SHALL BE INCLUDED IN THE COST OF PAVING RESTORATION

PAVING BASE DIMENSIONS AND REPAVING QUANTITIES						
PIPE SIZE	TRENCH WIDTH (FT.)	BASE WIDTH (FT.)	CU. YARDS / LIN. FT 10" BASE	CU. YARDS / LIN. FT 8" BASE	PAVING WIDTH (FT.)	PAVING SQ. YDS. / LIN. FT.
6	1.50	3.00	0.093	0.074	4.00	.44
8	2.00	3.50	0.108	0.086	4.50	.50
10	2.17	3.67	0.113	0.091	4.67	.52
12	2.33	3.83	0.118	0.094	4.83	.54
16	2.67	4.17	0.129	0.103	5.17	.57
20	3.00	4.50	0.139	0.111	5.50	.61
24	4.00	6.00	0.185	0.148	7.00	.78
30	4.50	6.50	0.201	0.160	7.50	.83
36	5.00	7.00	0.216	0.173	8.00	.89
42	5.50	7.50	0.231	0.185	8.50	.94
48	6.00	8.00	0.247	0.197	9.00	1.00

<b>PHILADELPHIA</b> <b>WATER</b> DEPARTMENT	<b>PAVING DIMENSIONS &amp; QUANTITIES</b>		
	<b>- CITY STREETS</b>		
	DRAWN BY: D&B GUARINO	DATE: FEB. 2022	
CHECKED BY: WD	DETAIL ID: INSTALL-06	REV.: 1	