

Water and Sewer Design Manual V3.12 Changes

This update to the design manual is to incorporate changes and corrections from V3.11

- In Section 5 D House Lateral Design, the requirements for Ductile Iron Laterals when the sewer is within 5 feet of the curb and all streets 16 feet or less has been removed. These shall now be constructed with vitrified clay laterals, unless otherwise required.

Additionally, these contacts have changed:

- Erik Haniman and Matthew Fulmer have had their titles added in Section 6 A.